

August 3, 2022

**RE: Lift Station and Force Main
Plankinton, South Dakota
SPN #15654**

BID LETTING: Wednesday, August 24, 2022 @ 2:00 PM

ADDENDUM NUMBER 1

The following modifications are to be made to the plans and specifications for the Lift Station and Force Main Project.

Section 33 32 11, Submersible Pump Station:

Paragraph 1.05 B: Replace with the following:

- B. The pump manufacturer shall have a factory trained service representative within 30 miles of the point of installation.

Paragraph 2.01 L: Replace with the following:

- L. The pumps shall be Model XFP 80 C by ABS or approved equal.

Paragraph 2.05 J. 4: Add the following:

- 4. The remote alarm notification system shall be provided by the City of Plankinton's systems integrator, Dakota Pump Inc from Mitchell, South Dakota.

Section 33 32 12, Submersible Pump Station Rehabilitation:

Paragraph 1.05 B: Replace with the following:

- B. The pump manufacturer shall have a factory trained service representative within 30 miles of the point of installation.

Paragraph 2.01 L: Replace with the following:

- L. The pumps shall be Model XFP 80 C by ABS/Sulzer, Model SL 1.30 by Grundfos or approved equal.

All other items of the plans and specifications remain unchanged.



Camden A. Hofer

Camden A. Hofer, Project Engineer
mucker, Paul, Nohr & Associates

The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications for the *Plankinton Lift Station and Force Main Project*.

FIRM NAME _____
BY _____
TITLE _____
DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.