

**August 19, 2022**

**RE: Lift Station and Force Main  
Plankinton, South Dakota  
SPN #15654**

**BID LETTING: Wednesday, August 24, 2022 @ 2:00 PM**

**ADDENDUM NUMBER 2**

The following modifications are to be made to the plans and specifications for the Lift Station and Force Main Project.

**Section 33 32 12, Submersible Pump Station Rehabilitation:**

Paragraph 1.03 B: Replace with the following:

- B. The power supply will be changed by the owner to single phase 120/240 volt. The motors shall have a maximum speed of 1800 RPM and a maximum rated power of 5 horsepower.

Paragraph 2.01 L: Replace with the following:

- L. The pumps shall be Model XFP 80 C by ABS/Sulzer or approved equal.

**All other items of the plans and specifications remain unchanged.**



*Camden A. Hofer, PE*  
\_\_\_\_\_  
Camden A. Hofer, Project Engineer  
Schmucker, Paul, Nohr & Associates

The undersigned hereby acknowledges receipt of Addendum Number 2 to the plans and specifications for the *Plankinton Lift Station and Force Main Project*.

FIRM NAME \_\_\_\_\_  
BY \_\_\_\_\_  
TITLE \_\_\_\_\_  
DATE \_\_\_\_\_

**ATTACH THIS SIGNED ADDENDUM NO. 2 TO THE BID FORM WHEN SUBMITTING.**