

**February 15, 2021**

**RE: CARRYOVER AND RAX ITEMS  
LOWER BRULE RURAL WATER SYSTEM  
LOWER BRULE, SOUTH DAKOTA  
SPN #15245**

**BID LETTING: THURSDAY, FEBRUARY 18, 2021 @ 2:00 PM**

***ADDENDUM NUMBER 1***

**Notice Regarding Bid Opening:**

The bid opening will be held publicly as planned. Due to the Corona Virus the Tribe will set up the bid opening for social distancing as recommended by various government agencies. This includes adequate seat spacing and sanitation procedures. Anyone attending the bid opening is asked to practice safe health measures as recommended by the Centers for Disease Control and Prevention (CDC). The Tribe requests that attendees be limited to one person per company.

**The following modifications are to be made to the specifications for the Carryover and RAX Items Project.**

**Section 25 13 00, Integrated Automation Control and Monitoring, Paragraph 1.03 B shall be added following Paragraph A:**

B. The flow meters required where shown in the plans will be furnished by the SCADA provider.

**Section 33 32 11, Submersible Pump Station Rehabilitation, Paragraph 2.01 C 2 shall be revised with passing a 2.5" sphere.**

**Section 33 32 11, Submersible Pump Station Rehabilitation, Paragraph 2.01 J shall be replaced with the following:**

J. The pumps shall be Model S3SD by Hydromatic, Model NP 3102 SH 3 by Flygt, Model XFP 80C by ABS Sulzer or approved equal.

**Section 40 05 64, Butterfly Valves, Paragraph 1.03 A shall be replaced with the following:**

A. All valves and related appurtenances shall be shipped in accordance with the appropriate requirements of the AWWA. Valve ends shall be covered to prevent intrusion of foreign matter into the valve.

**Section 40 05 64, Butterfly Valves, Paragraph 2.01 F:**

Add Henry Pratt Company Model 2FII as approved equal.

**Section 40 05 65, Check Valves, Paragraph 1.03 A shall be replaced with the following:**

A. All valves and related appurtenances shall be shipped in accordance with the appropriate requirements of the AWWA. Valve ends shall be covered to prevent intrusion of foreign matter into the valve.

**Section 40 05 65, Check Valves, Paragraph 2.01 B. Delete the words “with ground ends” from the third sentence.**

**Section 40 05 65, Check Valves, Paragraph 2.01 F:**

Add Henry Pratt Company Model 821G as approved equal.

**Section 40 05 65, Check Valves, Paragraph 2.01 G shall be deleted.**

**Section 40 05 67, Pressure and Control Valves, Paragraph 1.03 A shall be replaced with the following:**

A. All valves and related appurtenances shall be shipped in accordance with the appropriate requirements of the AWWA. Valve ends shall be covered to prevent intrusion of foreign matter into the valve.

**Section 40 05 67, Pressure and Control Valves, Paragraph 2.05 L 6:**

Add Model 206 RF by Singer Valve as an approved equal.

**Section 40 05 67, Pressure and Control Valves, Paragraph 2.05 M:**

Change the word “Relief” to “Reducing”.

**Section 40 05 67, Pressure and Control Valves, Paragraph 2.05 M 4 shall be replaced with the following:**

4. Control valve shall be Model 4” 90-01 by Cla-Val, Model 106 PR by Singer Valve or approved equal.

**Section 43 23 00, Pumps, Paragraph 2.03 A:**

Add Grundfos Paco LC 20709 as an approved equal.

**Section 43 41 45, Fiberglass Reinforced Plastic Tank, Paragraph 2.03 H 3 shall be replaced with the following:**

3. Exterior and interior ladder shall be included and constructed of fiberglass reinforced plastic according to current OSHA approved dimensions.

All other items of the plans and specifications remain unchanged.



*Camden A Hofer*

Camden A. Hofer, Project Engineer  
Schmucker, Paul, Nohr & Associates

-----  
The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications for the *CARRYOVER AND RAX ITEMS*.

FIRM NAME \_\_\_\_\_  
BY \_\_\_\_\_  
TITLE \_\_\_\_\_  
DATE \_\_\_\_\_

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.