Schmucker, Paul, Nohr and Associates
2100 North Sanborn Blvd — PO Box 398
Mitchell SD 57301-0398
Phone (605) 996-7761
Wats (800) 952-3598
Fax (605) 996-0015
www.spn-assoc.com

December 2, 2019

RE: WASTEWATER SYSTEM IMPROVEMENTS
PUKWANA, SOUTH DAKOTA
SPN #15156

BID LETTING: WEDNESDAY, DECEMBER 11, 2019 @ 2:00 PM

ADDENDUM NUMBER 1

The following modifications are to be made to the plans and specifications for the Wastewater System Improvements Project.

Section C-520 Agreement

Paragraph 4.01 A shall read: The work shall be substantially completed on or before October 1, 2020, for Bid Schedule A and July 31, 2020, for Bid Schedule B.

Section 11307 Rehabilitate Sewage Pump Station, Paragraph 2.09 A

Krohne Waterflux 3000 shall be listed as an approved flow meter.

Plan Sheet E-1

Add a 20-amp breaker for space #10 in Panel "M" for the three flow meters shown on Sheet 4. Include #12 electrical wire and 1-inch conduit for each flow meter.

All other items of the plans and specifications remain unchanged.



Camden A. Hofer, Project Engineer
Schmucker, Paul, Nohr & Associates

The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications for the Project.

FIRM NAME_____
BY_____
TITLE_____
DATE_____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.