



Schmucker, Paul, Nohr and Associates
 2100 North Sanborn Blvd — PO Box 398
 Mitchell SD 57301-0398
 Phone (605) 996-7761
 Wats (800) 952-3598
 Fax (605) 996-0015
 www.spn-assoc.com

June 11, 2018

**RE: SOLIDS REMOVAL
 WINNER, SOUTH DAKOTA
 SPN #14605**

BID LETTING: THURSDAY, JUNE 14, 2018 @ 1:00 PM

ADDENDUM NUMBER 1

The following modifications are to be made to the plans and specifications for the Solids Removal Project.

Section 15120, Paragraph 2.06 D shall be deleted and replaced with the following:

D. The yard hydrant shall be Model M-2000 from Merrill Manufacturing or approved equal.

Plan Sheet 3:

Note that prior to work on this project the ground surface will be rough graded to elevation 1947.15 around the perimeter of the concrete work with a variable slope away from the site ranging from 5:1 to 10:1.

Note that the gravel surfacing shall be placed around the east side of the proposed area and will consist of approximately 30 tons.

All other items of the plans and specifications remain unchanged.

Camden A. Hofer

 Camden A. Hofer, Project Engineer
 Schmucker, Paul, Nohr & Associates

The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications.

FIRM NAME _____
 BY _____
 TITLE _____
 DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.