

November 12, 2021

**RE: FIRST STREET AND LOGAN AVENUE UTILITY IMPROVEMENTS
GREGORY, SOUTH DAKOTA
SPN #15815**

BID LETTING: WEDNESDAY, NOVEMBER 17, 2021 @ 2:00 PM

ADDENDUM NUMBER 1


The following modifications are to be made to the specifications for the First Street and Logan Avenue Project.

Section 33 14 13, Water Distribution Piping, 2.02 Pressurized Polyvinyl Chloride (PVC) Pipe:

Delete in its entirety paragraph 2.02.A and replace with the following:

- A. Polyvinyl Chloride pipe shall be I.P.S. pressure Class 160, SDR 26 pipe conforming to the requirements of ASTM 2241. Due to potential material shortages, I.P.S. pressure Class 200, SDR 21 pipe conforming to the requirements of ASTM 2241 will be considered an approved equal at no additional cost to the Owner.

All other items of the plans and specifications remain unchanged.


Jeffrey P. McCormick, Project Manager
Schmucker, Paul, Nohr & Associates



The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications for the *FIRST STREET AND LOGAN AVENUE UTILITY IMPROVEMENTS*.

FIRM NAME _____
BY _____
TITLE _____
DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.