

June 23, 2022

**RE: Water Treatment Plant
Springfield, South Dakota
SPN #15627**

BID LETTING: Tuesday, June 28, 2022 @ 2:00 PM

ADDENDUM NUMBER 2

The following modifications are to be made to the plans and specifications for the Water Treatment Plant Project.

Section 09 77 00 Special Wall Surfacing:

Paragraph 2.01 B: Include NuFiber by Nudo as an approved equal.

Section 13 34 19 Pre-Engineered Metal Building Structures:

Paragraph 1.01 A: Include Nucor Building as an approved equal.

Divisions 23 and 26:

Refer to attached sheet by West Plains Engineering.


Sheet P102:


Show that the hatch has dimensions of 2' x 3'.

Sheets E8, E11 and E102:

Refer to the attached sheet by West Plains Engineering.

All other items of the plans and specifications remain unchanged.


Camden A. Hofer, Project Engineer
Schmucker, Paul, Nohr & Associates



The undersigned hereby acknowledges receipt of Addendum Number 2 to the plans and specifications for the *Springfield Water Treatment Plant Project*.

FIRM NAME _____
BY _____
TITLE _____
DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 2 TO THE BID FORM WHEN SUBMITTING.

Date: 6/22/2022**Project:** Springfield WTP**To:** Camden Hofer**Project #:** BS20068**From:** Todd Weidner, Connor Swiontek**Project Location:** Springfield, SD**Addendum Number:** 2

To: All prime contract bidders and all others to whom Drawings and Specifications have been issued by the Engineer. Acknowledge receipt of the Addendum by inserting its number and date on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as follows:

Product Approvals

The manufacturers and products, which are listed in the following texts, are approved for bidding. Final acceptance is contingent upon receipt and approval of final shop drawings. Manufacturer shall conform to all warranties, performances, size, etc., as the item specified. The burden of proof of the merit of the proposed substitution is upon the proposer.

Section	Description	Manufacturer
237223	Packaged ERV	Scott Springfield
237223	Packaged ERV	Innovent
235400	Furnaces	Daikin
233423	Power Ventilators	Plastic Air

Specifications

Section 23 3423 HVAC Power Ventilators

1. Polypropylene fans will be an acceptable alternative to fiberglass fans.

Section 26 3213

1. Delete paragraph 3.06 B in its entirety.

Drawings

Sheet E8

1. See H2 feeder: shall be 200A in lieu of 50A.

Sheet E11

1. See H1 panel schedule: breaker #6 shall be 175A.

Sheet E102

1. See H2 panel schedule: shall be 200A with 175A MCB, service entrance rated.

END OF DOCUMENT – TW/CS

